

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
Lab/ELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-001	001	1/26/2021	Room 96 Left	Classroom Faucet	Initial	ND	
210423001-002	002	1/26/2021	Room 96 Right	Classroom Faucet	Initial	ND	
210423001-003	003	1/26/2021	Room 95 Left	Classroom Faucet	Initial	ND	
210423001-004	004	1/26/2021	Room 95 Right Sink	Classroom Faucet	Initial	ND	
210423001-005	005	1/26/2021	Room 97 Left Sink	Classroom Faucet	Initial	ND	
210423001-006	006	1/26/2021	Room 97 Right Sink	Classroom Faucet	Initial	ND	
210423001-007	007	1/26/2021	Room 94 Right Sink	Classroom Faucet	Initial	ND	
210423001-008	008	1/26/2021	Room 94 Left Sink	Classroom Faucet	Initial	ND	
210423001-009	009	1/26/2021	Room 94 Right Sink	Classroom Faucet	Initial	1.2	
210423001-010	010	1/26/2021	Janitor's Closet Sink	Faucet	Initial	4.6	
210423001-011	011	1/26/2021	Room 93 Left Sink	Classroom Faucet	Initial	1.3	
210423001-012	012	1/26/2021	Room 93 Right Sink	Classroom Faucet	Initial	ND	
210423001-013	013	1/26/2021	Room 93 Lone Sink	Classroom Faucet	Initial	ND	
210423001-014	014	1/26/2021	Room 98 Left Sink	Classroom Faucet	Initial	ND	
210423001-015	015	1/26/2021	Room 98 Right Sink	Classroom Faucet	Initial	ND	
210423001-016	016	1/26/2021	Room 98 Lone Sink	Classroom Faucet	Initial	ND	
210423001-017	017	1/26/2021	Room 99 Left Sink	Classroom Faucet	Initial	2.3	
210423001-018	018	1/26/2021	Room 99 Right Sink	Classroom Faucet	Initial	ND	
210423001-019	019	1/26/2021	Room 92	Classroom Faucet	Initial	ND	
210423001-020	020	1/26/2021	Men's Room K wing	Bathroom Faucet	Initial	4.8	
210423001-021	021	1/26/2021	Ladies Room K wing	Bathroom Faucet	Initial	ND	
210423001-022	022	1/26/2021	Boiler Elemen	Faucet	Initial	4.6	
210423001-023	023	1/26/2021	Elem Facility	Faucet	Initial	1	
210423001-024	024	1/26/2021	Elem Coach's	Faucet	Initial	11.3	
210423001-025	025	1/26/2021	Boy's Lower Left	Bathroom Faucet	Initial	ND	
210423001-026	026	1/26/2021	Boy's Lower Right	Bathroom Faucet	Initial	ND	
210423001-027	027	1/26/2021	Girl's Room Lower Left Sink	Bathroom Faucet	Initial	ND	
210423001-028	028	1/26/2021	Girl's Room Lower Right Sink	Bathroom Faucet	Initial	ND	
210423001-029	029	1/26/2021	Room 126	Classroom Faucet	Initial	ND	
210423001-030	030	1/26/2021	Room 114	Classroom Faucet	Initial	ND	
210423001-031	031	1/26/2021	Room 115	Classroom Faucet	Initial	ND	
210423001-032	032	1/26/2021	Room 125	Classroom Faucet	Initial	1.9	
210423001-033	033	1/26/2021	Room 124	Classroom Faucet	Initial	ND	
210423001-034	034	1/26/2021	Room 116	Classroom Faucet	Initial	ND	
210423001-035	035	1/26/2021	Room 117	Classroom Faucet	Initial	1.3	
210423001-036	036	1/26/2021	Room 123	Classroom Faucet	Initial	1	
210423001-037	037	1/26/2021	Room 122	Classroom Faucet	Initial	ND	
210423001-038	038	1/26/2021	Room 118	Classroom Faucet	Initial	ND	
210423001-039	039	1/26/2021	Room 119	Classroom Faucet	Initial	1.7	

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
Lab/ELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-040	040	1/26/2021	Room 121	Classroom Faucet	Initial	ND	
210423001-041	041	1/26/2021	Janitor's Closet Lower Hall	Faucet	Initial	2.2	
210423001-042	042	1/26/2021	Boy's Room Left next to Room 120	Bathroom Faucet	Initial	ND	
210423001-043	043	1/26/2021	Boy's Room Right next to Room 120	Bathroom Faucet	Initial	ND	
210423001-044	044	1/26/2021	Girl's Room Left next to Room 120	Bathroom Faucet	Initial	ND	
210423001-045	045	1/26/2021	Girl's Room Right next to Room 120	Bathroom Faucet	Initial	ND	
210423001-046	046	1/26/2021	Room 120	Classroom Faucet	Initial	ND	
210423001-047	047	1/26/2021	Room 105	Classroom Faucet	Initial	2	
210423001-048	048	1/28/2021	Room 104 Bathroom	Bathroom Faucet	Initial	3	
210423001-049	049	1/28/2021	Room 104 Sink	Classroom Faucet	Initial	ND	
210423001-050	050	1/28/2021	Room 103 Sink	Classroom Faucet	Initial	ND	
210423001-051	051	1/28/2021	Room 103 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-052	052	1/28/2021	Room 103 Bathroom	Bathroom Faucet	Initial	ND	
210423001-053	053	1/28/2021	Room 102 Bathroom	Bathroom Faucet	Initial	1.1	
210423001-054	054	1/28/2021	Room 102 Sink	Classroom Faucet	Initial	ND	
210423001-055	055	1/28/2021	Room 102 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-056	056	1/28/2021	Room 101	Classroom Faucet	Initial	ND	
210423001-057	057	1/28/2021	Room 100	Classroom Faucet	Initial	2.1	
210423001-058	058	1/28/2021	Men's Room Across from 113	Bathroom Faucet	Initial	1.3	
210423001-059	059	1/28/2021	Women's Room Across from 113	Bathroom Faucet	Initial	ND	
210423001-060	060	1/28/2021	Room 113 Sink	Classroom Faucet	Initial	ND	
210423001-061	061	1/28/2021	Room 113 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-062	062	1/28/2021	Room 112 Sink	Classroom Faucet	Initial	ND	
210423001-063	063	1/28/2021	Room 112 Drinking Fountain	Drinking Fountain	Initial	1.2	
210423001-064	064	1/28/2021	Room 111 Sink	Classroom Faucet	Initial	1.3	
210423001-065	065	1/28/2021	Room 111 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-066	066	1/28/2021	Guidance	Faucet	Initial	1.6	
210423001-067	067	1/28/2021	Room 110 Sink	Classroom Faucet	Initial	1.4	
210423001-068	068	1/28/2021	Room 110 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-069	069	1/28/2021	Girl's Room Right Right Sink	Bathroom Faucet	Initial	ND	
210423001-070	070	1/28/2021	Girl's Room Right Left Sink	Bathroom Faucet	Initial	ND	
210423001-071	071	1/28/2021	Girl's Room Left Right Sink	Bathroom Faucet	Initial	ND	
210423001-072	072	1/28/2021	Girl's Room Left Left Sink	Bathroom Faucet	Initial	ND	
210423001-073	073	1/28/2021	Room 109 Sink	Classroom Faucet	Initial	1.7	
210423001-074	074	1/28/2021	Room 109 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-075	075	1/28/2021	Room 130	Classroom Faucet	Initial	4	
210423001-076	076	1/28/2021	Room 108 Sink	Classroom Faucet	Initial	1	
210423001-077	077	1/28/2021	Room 108 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-078	078	1/28/2021	Boy's Room Left Sink	Bathroom Faucet	Initial	ND	

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
Lab/ELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-079	079	1/28/2021	Boy's Room Right Sink	Bathroom Faucet	Initial	ND	
210423001-080	080	1/28/2021	Boy's Room Middle Sink	Bathroom Faucet	Initial	ND	
210423001-081	081	1/28/2021	Room 107 Sink	Classroom Faucet	Initial	1.1	
210423001-082	082	1/28/2021	Room 107 Drinking Fountain	Drinking Fountain	Initial	1	
210423001-083	083	1/28/2021	Room 106 Sink	Classroom Faucet	Initial	ND	
210423001-084	084	1/28/2021	Room 106 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-085	085	1/28/2021	Room 801 Bathroom	Bathroom Faucet	Initial	1.5	
210423001-086	086	1/28/2021	Room 801 Sink	Classroom Faucet	Initial	ND	
210423001-087	087	1/28/2021	Room 802 Bathroom	Bathroom Faucet	Initial	10.7	
210423001-088	088	1/28/2021	Room 802 Sink	Classroom Faucet	Initial	13.2	
210423001-089	089	1/28/2021	Room 803 Right Sink	Classroom Faucet	Initial	1.5	
210423001-090	090	1/28/2021	Room 803 Left Sink	Classroom Faucet	Initial	5.5	
210423001-091	091	1/28/2021	Room 804 Right Sink	Classroom Faucet	Initial	3	
210423001-092	092	1/28/2021	Room 804 Left Sink	Classroom Faucet	Initial	4.2	
210423001-093	093	1/28/2021	900 Hall Faculty Bathroom	Bathroom Faucet	Initial	ND	
210423001-094	094	1/28/2021	900 Hall Girl's Room Right Sink	Bathroom Faucet	Initial	ND	
210423001-095	095	1/28/2021	900 Hall Girl's Room Left Sink	Bathroom Faucet	Initial	ND	
210423001-096	096	1/28/2021	900 Hall Boy's Room Right Sink	Bathroom Faucet	Initial	2	
210423001-097	097	1/28/2021	900 Hall Boy's Room Left Sink	Bathroom Faucet	Initial	ND	
210423001-098	098	1/28/2021	Room 900 Front Sink	Classroom Faucet	Initial	24.9	Labeled as "do not drink"
210423001-099	099	1/28/2021	Room 900 Left Counter Sink	Classroom Faucet	Initial	15.5	Labeled as "do not drink"
210423001-100	100	1/28/2021	Room 900 Left Front Island Left Sink	Classroom Faucet	Initial	34.4	Labeled as "do not drink"
210423001-101	101	1/28/2021	Room 900 Left Front Island Right Sink	Classroom Faucet	Initial	39.8	Labeled as "do not drink"
210423001-102	102	1/28/2021	Room 900 Left Back Island Left Sink	Classroom Faucet	Initial	9.4	
210423001-103	103	1/28/2021	Room 900 Left Back Island Right Sink	Classroom Faucet	Initial	36.5	Labeled as "do not drink"
210423001-104	104	1/28/2021	Room 900 Middle Front Island Left Sink	Classroom Faucet	Initial	3.4	
210423001-105	105	1/28/2021	Room 900 Middle Front Island Right Sink	Classroom Faucet	Initial	43	Labeled as "do not drink"
210423001-106	106	1/28/2021	Room 900 Middle Back Island Left Sink	Classroom Faucet	Initial	30.2	Labeled as "do not drink"
210423001-107	107	1/28/2021	Room 900 Middle Back Island Right Sink	Classroom Faucet	Initial	29.1	Labeled as "do not drink"
210423001-108	108	1/28/2021	Room 900 Right Front Island Left Sink	Classroom Faucet	Initial	9.7	
210423001-109	109	1/28/2021	Room 900 Right Front Island Right Sink	Classroom Faucet	Initial	35.5	Labeled as "do not drink"
210423001-110	110	1/28/2021	Room 900 Right Back Island Left Sink	Classroom Faucet	Initial	14.2	
210423001-111	111	1/28/2021	Room 900 Right Back Island Right Sink	Classroom Faucet	Initial	25.6	Labeled as "do not drink"
210423001-112	112	1/28/2021	Lower 900 Hall Janitor's Closet	Faucet	Initial	1.7	
210423001-113	113	1/29/2021	Room 708 From Rt A	Faucet	Initial	ND	
210423001-114	114	1/29/2021	Room 708 From Rt B	Faucet	Initial	ND	
210423001-115	115	1/29/2021	Room 708 From Rt C	Faucet	Initial	ND	
210423001-116	116	1/29/2021	Room 708 From Rt D	Faucet	Initial	ND	
210423001-117	117	1/29/2021	Room 708 From Rt E	Faucet	Initial	ND	

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
Lab/ELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-118	118	1/29/2021	Room 708 From Rt F	Faucet	Initial	ND	
210423001-119	119	1/29/2021	Room 708 From Rt G	Faucet	Initial	ND	
210423001-120	120	1/29/2021	Janitor's Closet 700 Hall	Faucet	Initial	5.9	
210423001-121	121	1/29/2021	Room 705	Classroom Faucet	Initial	13.9	
210423001-122	122	1/29/2021	Girl's Room 700 Hall Right Sink	Bathroom Faucet	Initial	2.4	
210423001-123	123	1/29/2021	Girl's Room 700 Hall Left Sink	Bathroom Faucet	Initial	1.3	
210423001-124	124	1/29/2021	Boy's Room 700 Hall Right Sink	Bathroom Faucet	Initial	1.4	
210423001-125	125	1/29/2021	Boy's Room 700 Hall Left Sink	Bathroom Faucet	Initial	2.6	
210423001-126	126	1/29/2021	Room 704 Triple Sink Left	Classroom Faucet	Initial	1.7	
210423001-127	127	1/29/2021	Room 704 Triple Sink Middle	Classroom Faucet	Initial	1	
210423001-128	128	1/29/2021	Room 704 Triple Sink Right	Classroom Faucet	Initial	1.3	
210423001-129	129	1/29/2021	Room 704 Single Sink	Classroom Faucet	Initial	1.3	
210423001-130	130	1/29/2021	Room 702 Triple Sink Left	Classroom Faucet	Initial	3	
210423001-131	131	1/29/2021	Room 702 Triple Sink Middle	Classroom Faucet	Initial	1.6	
210423001-132	132	1/29/2021	Room 702 Triple Sink Right	Classroom Faucet	Initial	2.5	
210423001-133	133	1/29/2021	Room 702 Single Sink	Classroom Faucet	Initial	4.7	
210423001-134	134	1/29/2021	Room 700	Classroom Faucet	Initial	ND	
210423001-135	135	1/29/2021	O&M Break Room	Faucet	Initial	3.6	
210423001-136	136	2/23/2021	HS Kitchen Bathroom	Bathroom Faucet	Initial	ND	
210423001-137	137	2/23/2021	HS Dishroom	Kitchen Faucet	Initial	2	
210423001-138	138	2/23/2021	HS Dishroom	Kitchen Faucet	Initial	1.3	
210423001-139	139	2/23/2021	HS Dishroom	Kitchen Faucet	Initial	ND	
210423001-140	140	2/23/2021	HS Kitchen	Kitchen Faucet	Initial	3.6	
210423001-141	141	2/23/2021	HS Office	Faucet	Initial	ND	
210423001-142	142	2/23/2021	HS Office Bathroom	Bathroom Faucet	Initial	6	
210423001-143	143	2/23/2021	MS Boiler Room	Faucet	Initial	8.1	
210423001-144	144	2/23/2021	600 Hall Girl's Room	Bathroom Faucet	Initial	ND	
210423001-145	145	2/23/2021	600 Hall Girl's Room	Bathroom Faucet	Initial	ND	
210423001-146	146	2/23/2021	Facility Ladies Room	Bathroom Faucet	Initial	3	
210423001-147	147	2/23/2021	Facility Sink	Faucet	Initial	ND	
210423001-148	148	2/23/2021	Facility Men's Room	Bathroom Faucet	Initial	4.9	
210423001-149	149	2/23/2021	500 Hall Boy's Room Right	Bathroom Faucet	Initial	2.1	
210423001-150	150	2/23/2021	500 Hall Boy's Room Middle	Bathroom Faucet	Initial	ND	
210423001-151	151	2/23/2021	500 Hall Boy's Room Left	Bathroom Faucet	Initial	ND	
210423001-152	152	2/23/2021	Room 505 1st Sink	Classroom Faucet	Initial	141	Labeled as "do not drink"
210423001-153	153	2/23/2021	Room 505 3rd Sink	Classroom Faucet	Initial	37.7	Labeled as "do not drink"
210423001-154	154	2/23/2021	Room 505 4th Sink	Classroom Faucet	Initial	68	Labeled as "do not drink"
210423001-155	155	2/23/2021	Room 505 Left Sink	Classroom Faucet	Initial	56.6	Labeled as "do not drink"
210423001-156	156	2/23/2021	Room 505 Right Sink	Classroom Faucet	Initial	33.2	Labeled as "do not drink"

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
Lab/ELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-157	157	2/23/2021	Room 505 Metal Sink	Classroom Faucet	Initial	110	Labeled as "do not drink"
210423001-158	158	2/23/2021	Room 505 Front Sink	Classroom Faucet	Initial	4.6	
210423001-159	159	2/23/2021	Room 505/504 Breakroom Sink	Classroom Faucet	Initial	33	Labeled as "do not drink"
210423001-160	160	2/23/2021	Room 504 1st Sink	Classroom Faucet	Initial	38.2	Labeled as "do not drink"
210423001-161	161	2/23/2021	Room 504 2nd Sink	Classroom Faucet	Initial	2000	Labeled as "do not drink"
210423001-162	162	2/23/2021	Room 504 3rd Sink	Classroom Faucet	Initial	36.7	Labeled as "do not drink"
210423001-163	163	2/23/2021	Room 504 4th Sink	Classroom Faucet	Initial	97.1	Labeled as "do not drink"
210423001-164	164	2/23/2021	Room 504 5th Sink	Classroom Faucet	Initial	43.5	Labeled as "do not drink"
210423001-165	165	2/23/2021	Room 504 6th Sink	Classroom Faucet	Initial	49.2	Labeled as "do not drink"
210423001-166	166	2/23/2021	Room 504 Metal Sink	Classroom Faucet	Initial	4.2	
210423001-167	167	2/23/2021	Room 504 Front Sink	Classroom Faucet	Initial	21.7	Labeled as "do not drink"
210423001-168	168	2/23/2021	District Office Men's Room	Bathroom Faucet	Initial	2.6	
210423001-169	169	2/23/2021	District Office Women's Room	Bathroom Faucet	Initial	1.9	
210423001-170	170	2/23/2021	District Office Break Room	Faucet	Initial	2	
210423001-171	171	2/23/2021	HS Library Office	Faucet	Initial	5.8	
210423001-172	172	2/24/2021	Room 503 Front Sink	Classroom Faucet	Initial	8.4	
210423001-173	173	2/24/2021	Room 503 Station Sink 1	Classroom Faucet	Initial	52.1	Labeled as "do not drink"
210423001-174	174	2/24/2021	Room 503 Station Sink 2	Classroom Faucet	Initial	39.5	Labeled as "do not drink"
210423001-175	175	2/24/2021	Room 503 Station Sink 3	Classroom Faucet	Initial	34.5	Labeled as "do not drink"
210423001-176	176	2/24/2021	Room 503 Station Sink 4	Classroom Faucet	Initial	22.4	Labeled as "do not drink"
210423001-177	177	2/24/2021	Room 503 Station Sink 5	Classroom Faucet	Initial	21.4	Labeled as "do not drink"
210423001-178	178	2/24/2021	Room 503 Station Sink 6	Classroom Faucet	Initial	13.6	
210423001-179	179	2/24/2021	Room 503 Station Sink 7	Classroom Faucet	Initial	10.6	
210423001-180	180	2/24/2021	Room 503 Station Sink 8	Classroom Faucet	Initial	16.6	Labeled as "do not drink"
210423001-181	181	2/24/2021	Room 503 Station Sink 9	Classroom Faucet	Initial	9.2	
210423001-182	182	2/24/2021	Room 503 Station Sink 10	Classroom Faucet	Initial	11.6	
210423001-183	183	2/24/2021	Room 503 Station Sink 11	Classroom Faucet	Initial	66.4	Labeled as "do not drink"
210423001-184	184	2/24/2021	Room 503 Station Sink 12	Classroom Faucet	Initial	31	Labeled as "do not drink"
210423001-185	185	2/24/2021	Room 503 Station Sink 13	Classroom Faucet	Initial	13.2	
210423001-186	186	2/24/2021	Room 503 Station Sink 14	Classroom Faucet	Initial	15.7	Labeled as "do not drink"
210423001-187	187	2/24/2021	Room 502 Front Classroom Sink 1	Classroom Faucet	Initial	3.4	
210423001-188	188	2/24/2021	Room 502 Front Classroom Sink 2	Classroom Faucet	Initial	4.9	
210423001-189	189	2/24/2021	Room 502 Station Sink 1	Classroom Faucet	Initial	33.8	Labeled as "do not drink"
210423001-190	190	2/24/2021	Room 502 Station Sink 2	Classroom Faucet	Initial	43.7	Labeled as "do not drink"
210423001-191	191	2/24/2021	Room 502 Station Sink 3	Classroom Faucet	Initial	8.9	
210423001-192	192	2/24/2021	Room 502 Station Sink 4	Classroom Faucet	Initial	14.7	
210423001-193	193	2/24/2021	Room 502 Station Sink 5	Classroom Faucet	Initial	8.2	
210423001-194	194	2/24/2021	Room 502 Station Sink 6	Classroom Faucet	Initial	11.2	
210423001-195	195	2/24/2021	Room 502 Station Sink 7	Classroom Faucet	Initial	21.9	Labeled as "do not drink"

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
Lab/ELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-196	196	2/24/2021	Room 502 Station Sink 8	Classroom Faucet	Initial	17.1	Labeled as "do not drink"
210423001-197	197	2/24/2021	Room 502 Station Sink 9	Classroom Faucet	Initial	32.6	Labeled as "do not drink"
210423001-198	198	2/24/2021	Room 502 Station Sink 10	Classroom Faucet	Initial	20.8	Labeled as "do not drink"
210423001-199	199	2/24/2021	Room 502 Station Sink 11	Classroom Faucet	Initial	18	Labeled as "do not drink"
210423001-200	200	2/24/2021	Room 502 Station Sink 12	Classroom Faucet	Initial	33.5	Labeled as "do not drink"
210423001-201	201	2/24/2021	Room 502 Station Sink 13	Classroom Faucet	Initial	12.6	
210423001-202	202	2/24/2021	500 Hall Janitor's Closet	Faucet	Initial	12.7	
210423001-203	203	2/24/2021	400 Hall Ladies Room	Bathroom Faucet	Initial	4.5	
210423001-204	204	2/24/2021	400 Hall Men's Room	Bathroom Faucet	Initial	3.4	
210423001-205	205	2/24/2021	303 Janitor's Closet	Faucet	Initial	2.4	
210423001-206	206	2/24/2021	Room 307 Right Sink	Classroom Faucet	Initial	9.4	
210423001-207	207	2/24/2021	Room 307 Left Sink	Classroom Faucet	Initial	17.6	Labeled as "do not drink"
210423001-208	208	2/24/2021	Stage Men's Room	Bathroom Faucet	Initial	1.9	
210423001-209	209	2/24/2021	Stage Women's Room	Bathroom Faucet	Initial	ND	
210423001-210	210	4/15/2021	Room 96 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-211	211	4/15/2021	Room 95 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-212	212	4/15/2021	Room 97 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-213	213	4/15/2021	Room 94 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-214	214	4/15/2021	Room 98 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-215	215	4/15/2021	Room 93 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-216	216	4/15/2021	Room 99 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-217	217	4/15/2021	Room 120 Drinking Fountain	Drinking Fountain	Initial	1.1	
210423001-218	218	4/15/2021	Room 121 Drinking Fountain	Drinking Fountain	Initial	1	
210423001-219	219	4/15/2021	Room 119 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-220	220	4/15/2021	Room 118 Drinking Fountain	Drinking Fountain	Initial	1.1	
210423001-221	221	4/15/2021	Room 122 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-222	222	4/15/2021	Room 123 Drinking Fountain	Drinking Fountain	Initial	1.6	
210423001-223	223	4/15/2021	Room 117 Drinking Fountain	Drinking Fountain	Initial	2.7	
210423001-224	224	4/15/2021	Room 116 Drinking Fountain	Drinking Fountain	Initial	1.1	
210423001-225	225	4/15/2021	Room 124 Drinking Fountain	Drinking Fountain	Initial	1.3	
210423001-226	226	4/15/2021	Room 125 Drinking Fountain	Drinking Fountain	Initial	1.6	
210423001-227	227	4/15/2021	Room 115 Drinking Fountain	Drinking Fountain	Initial	1.4	
210423001-228	228	4/15/2021	Room 114 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-229	229	4/15/2021	Room 126 Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-230	230	4/16/2021	500 Hall A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-231	231	4/16/2021	500 Hall B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-232	232	4/16/2021	Girl's A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-233	233	4/16/2021	Girl's B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-234	234	4/16/2021	Girl's C Drinking Fountain	Drinking Fountain	Initial	ND	

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
LabELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-235	235	4/16/2021	Boy's A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-236	236	4/16/2021	Boy's B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-237	237	4/16/2021	200 A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-238	238	4/16/2021	200 B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-239	239	4/16/2021	600 A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-240	240	4/16/2021	600 B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-241	241	4/16/2021	700 Art A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-242	242	4/16/2021	700 Art B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-243	243	4/16/2021	700 Home Ec A	Classroom Faucet	Initial	ND	
210423001-244	244	4/16/2021	700 Home Ec B	Classroom Faucet	Initial	ND	
210423001-245	245	4/16/2021	800 Hall A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-246	246	4/16/2021	800 Hall B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-247	247	4/16/2021	700 Hall A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-248	248	4/16/2021	700 Hal B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-249	249	4/16/2021	700 Hall C Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-250	250	4/16/2021	Across from 108A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-251	251	4/16/2021	Across from 108B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-252	252	4/16/2021	By 37A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-253	253	4/16/2021	By 37B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-254	254	4/16/2021	By 120A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-255	255	4/16/2021	By 120B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-256	256	4/16/2021	Out from Elem Café A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-257	257	4/16/2021	Out from Elem Café B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-258	258	4/16/2021	Inside Elem Café A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-259	259	4/16/2021	Inside Elem Café B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-260	260	4/16/2021	Across from 103A Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-261	261	4/16/2021	Across from 103B Drinking Fountain	Drinking Fountain	Initial	ND	
210423001-262	262	4/22/2021	Women's Room Auditorium Right Sink	Bathroom Faucet	Initial	2.3	
210423001-263	263	4/22/2021	Women's Room Auditorium Middle Sink	Bathroom Faucet	Initial	1.1	
210423001-264	264	4/22/2021	Women's Room Auditorium Left Sink	Bathroom Faucet	Initial	ND	
210423001-265	265	4/22/2021	Men's Room Auditorium Right Sink	Bathroom Faucet	Initial	ND	
210423001-266	266	4/22/2021	Men's Room Auditorium Middle Sink	Bathroom Faucet	Initial	2.3	
210423001-267	267	4/22/2021	Men's Room Auditorium Left Sink	Bathroom Faucet	Initial	1.3	
210423001-268	268	4/22/2021	Auditorium Drinking Fountain	Drinking Fountain	Initial	13	
210423001-269	269	4/22/2021	Girl's Locker Room Right	Bathroom Faucet	Initial	13	
210423001-270	270	4/22/2021	Girl's Locker Room Left	Bathroom Faucet	Initial	9.3	
210423001-271	271	4/22/2021	Women's Coach Room	Faucet	Initial	ND	
210423001-272	272	4/22/2021	Referee Room	Faucet	Initial	4.4	
210423001-273	273	4/22/2021	Boys Locker Room Right	Faucet	Initial	17.1	Labeled as "do not drink"

Lead in Water Sample Log							
School Name:	Galway Central School District			Date Last Updated:	13-Jan-22		
LabELAP ID:	10709			Method of Analysis:	EPA 200.8 Rev 5.4		
Lab Sample ID	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result (ppb)	Action Taken
210423001-274	274	4/22/2021	Boys locker Room Left	Faucet	Initial	26.3	Labeled as "do not drink"
210423001-275	275	4/22/2021	Coaches Office	Faucet	Initial	5.9	
210423001-276	276	4/22/2021	200 Hall Janitors Closet	Faucet	Initial	10.3	
210423001-277	277	4/22/2021	Ice Machine	Ice machine	Initial	ND	
210423001-278	278	4/22/2021	Mens Room	Bathroom Faucet	Initial	ND	
210423001-279	279	4/22/2021	Ladies Room	Bathroom Faucet	Initial	ND	
210423001-280	280	4/22/2021	Janitors Closet	Faucet	Initial	ND	
210423001-281	281	4/22/2021	Mechanics Bay	Faucet	Initial	ND	
210423001-282	282	4/22/2021	Wash bay sink	Faucet	Initial	ND	
210423001-283	283	4/22/2021	Concession Rm	Faucet	Initial	4.6	
210423001-284	284	4/22/2021	Mens Rm Outside	Bathroom Faucet	Initial	1.8	
210423001-285	285	4/22/2021	Womans Rd Outside	Bathroom Faucet	Initial	3.3	
210514010-286	286	5/13/2021	Hand washing sink Elementary Kitchen	Faucet	Initial	ND	
210514010-287	287	5/13/2021	Single Sink Elementary Kitchen	Faucet	Initial	ND	
210514010-288	288	5/13/2021	Left 2 bay sink elementary kitchen	Faucet	Initial	ND	
210514010-289	289	5/13/2021	Right Faucet 2 Bay Sink	Faucet	Initial	ND	